

## **Universal Communication Gateway**



## **Features**

- Translates Modbus protocol from boiler/burner to building management system protocol
- Supports BACnet, Metasys, LonWorks and Modbus protocols
- Preconfigured for use with the following controls with Modbus communication port: Honeywell Sola hydronic control, Siemens LMV series burner control, Honeywell RM7800 series burner control and Siemens RWF40 PID control

The Universal Communication Gateway is an external, high performance, low cost building automation multi-protocol gateway that has been preprogrammed to support BACnet<sup>®1</sup> MSTP, BAC-net<sup>®2</sup> IP, Metasys<sup>®</sup> N2 by JCI, Modbus TCP, and LonWorks<sup>®</sup>. All Honeywell Sola, Siemens RWF40, Siemens LMV, and the Honeywell 7800 Series boiler configurations for the various protocols are stored within the gateway and are selectable

## **Benefits**

- Cost effective integration of Boiler/Burner controls into building management system
- No additional software, downloads or programming required at the job site
- Preconfigured at the factory for common data points
- Bi-directional data flow between devices on selected points
- Everything included in one control panel with connections for 120 Vac and device communication cable



via DIP switches for fast and easy installation. It is not necessary to download any configuration files to support the required applications.

The Universal Communication Gateway is provided as a  $10^{"} \times 12^{"} \times 6^{"}$  NEMA Type 1 control panel that must be mounted and supplied with 120 Vac. Additional specifications can be found on the reverse side of this sheet.

<sup>&</sup>lt;sup>1</sup> BACnet is a registered trademark of ASHRAE

<sup>&</sup>lt;sup>2</sup> Metasys is a registered trademark of Johnson Controls Inc.

## Universal Communications Gateway

- 1. NEMA Type 1 Panel
- 2. Panel Door Latch
- 3. On-off Switch
- 4. Fuse
- 5. 12 Vac Stepdown Transformer
- 6. 9 Vac Adaptor
- 7. RS-232/RS-485 Converter
- 8. Configuration Manager Protocessor
- 9. Sola Port
- 10. Field Device Port
- 11. Building Management Port
- 12. 120 Vac Main Power Port



| Terminal                 | Electrical Connections   |                          |
|--------------------------|--|--------------------------|
|                          | BACnet/Metasys N2/Modbus TCP   | LonWorks                 |
| RJ45                     | 10/100 Ethernet Port   | 10/100 Ethernet Port     |
| J1-1                     | 120 Vac Line Voltage   | 120 Vac Line Voltage     |
| J1-2                     | 120 Vac Return Line  | 120 Vac Return Line      |
| J1-3                     | Physical Earth Ground  | Physical Earth Ground    |
| RJ45                     | Sola Port  | Sola Port                |
| J3-3                     | Device RS485 Data+   | Device RS485 Data+       |
| J3-2                     | Device RS485 Data-   | Device RS485 Data-       |
| J3-1                     | Device RS485 Ground  | Device RS485 Ground      |
| J2-3                     | BMS RS485 Data+  | BMS FTT-10 LonWorks Port |
| J2-2                     | BMS RS485 Data-  | BMS FTT-10 LonWorks Port |
| J2-1                     | BMS RS485 Ground   | N/A                      |
| Approvals:               | CE (EN55022; EN55024; EN60950), UL916, FCC Class A Part 15, DNP3<br>Conformance Tested, OPC Self-tested for Compliance, RoHS Compliant, CSA 205 Approved |                          |
|                          | BTL Marked   | LonMark Certified        |
| Requirements<br>Power    | 120 Vac @ <3.5 Watts   |                          |
| Physical<br>Dimensions   | 10 in. x 12 in. x 6 in.  |                          |
| Weight                   | 13.2 lbs.  |                          |
| Operating<br>Temperature | -40°C to 75°C (-40°F to 167°F)   |                          |
| Surge<br>Suppression     | EN61000-4-2 ESD EN61000-4-3 EMC EN61000-4-4 EFT  |                          |
| Humidity                 | 5-90% RH (non-condensing)  |                          |

Specifications subject to change without notice



783 N. Chili Ave., Peru, Indiana 46970 U.S.A. Phone: 765-473-6651 • Internet:www.bryanboilers.com Fax: 765-473-3074 • E-mail:inquiry@bryansteam.com