

# **BFIT CONDENSING BOILERS - SUBMITTAL DATA SHEET**

RATINGS AND CAPACITIES							
Input - Low fire:	80,000	BTU/HR					
Input - High Fire:	800,000	BTU/HR					
Output - High Fire:	776,000	BTU/HR					
Boiler Horsepower:	23.2	BHP					
Thermal Efficiency:	97.0%						
Heating Surface:	60.9	Sq.Ft.					
Water Content:	6.6	Gallons					
Fuel:	Natural Gas or LP Gas						
Firing Rate:	Full Modulation						
Burner Turndown:	10:1						
Low NOx Emissions:	< 10 ppm						
Inlet Gas Pressure (NG):	4" wc	Min.					
Inlet Gas Pressure (LP):	8" wc	Min.					
	14" wc	Max.					
Shipping Weight, Approximate:	560	lbs					
ASME Section IV (Max 160 PSIG / 210°F)		<sup>A</sup> s <sub>M</sub>					
Setpoint range is 60-185°F		ليتي ا					
Adjustable, manual reset high limit setting of ≤ 200°F.							
ASME H stamp MAWT is 210°F for the vessel. (F	For max setpoint, see Setpo	pint range.)					
ETL Certified to ANSI Z21.13 / CSA 4.9		. ED.					
ETL Certified to UL 795 / CSA 3.1		Intertek					
DIMENSIONS / CONNECTIONS							
Height:	38-1/2"	(Note 1)					
Width:	26-3/8"	(Note 2)					
Length:	53-7/8"	(Note 3)					
Supply Connection:	2" NPT						
Return Connection:	2" NPT						
Vent / Air Intake Connections:	6"						
Condensate / Boiler Drain Connection:	1"						
Gas Connection:	1" NPT						

FLOWS AND PRESSURE DROPS						
Delta T	Flow (GPM)	r P (Ft. Hd)				
20°F $ riangle$ T (Max)	78	12.8				
$25^{\circ}F \bigtriangleup T$	62	9.2				
$30^{\circ}F \bigtriangleup T$	52	7.0				
$35^{\circ}F \bigtriangleup T$	44	5.6				
$40^{\circ}F \bigtriangleup T$	39	4.6				
$45^{\circ}F \bigtriangleup T$	34	3.9				
$50^{\circ}F \bigtriangleup T$	31	3.3				
55°F $ riangle$ T (Min)	28	2.9				

**NOTES:** 1. Height dimension is from floor to top of jacket.

2. Length is from jacket front to jacket rear.

3. Dimensions shown are for reference only

# **BFIT CONDENSING BOILERS - SUBMITTAL DATA SHEET**

# STANDARD EQUIPMENT

### PRESSURE VESSEL DESIGN

Stainless Steel Heat Exchanger

ASME Section IV Certified, "H" Stamp

MAWP 160 PSIG & Max Temp 210°F

Setpoint range is 60-185°F

Adjustable, manual reset high limit setting of  $\leq 200^{\circ}$ F.

ASME H stamp MAWT is 210°F for the vessel. (For max setpoint, see Setpoint range.)

Ten Year Limited Pressure Vessel Warranty

## **COMBUSTION DESIGN**

Stainless Steel Pre-Mix Burner Low NOx Emissions ( < 10 ppm) Full Modulation, 10:1 Turndown Natural Gas or Propane 4" wc (8" wc Propane) to 14" wc inlet gas pressure **Direct Spark Ignition System** High/Low gas pressure switches, manual reset Variable Speed Combustion Blower **Blocked Vent Switch** 

#### VENTING

Category II or IV Venting Indivdual or Common (Engineered) Vent System Vertical or Horizontal

3-in-1 Vent Connector: Accepts CPVC, PP or Stainless Steel

Includes built-in vent aas sensor test port Combustion Air Intake - Sealed or Room

\* Flue system material shall be capable of continuous operation at 210°F or higher and shall be certified to UL 1738 - venting system for gas-burning appliances cat II, III and IV.

## **OPTIONAL EQUIPMENT**

Hydronic Kit (Boiler Circulation	Pump, Pump Flange Kit and Condensate	e Neutralizer)					
External High Limit Temperature	e Control, Manual Reset						
Condensate Neutralizer							
 Supply Header Temperature Se	ensor:	Direct Imme	ersion Well Imme	ersion (with Well)			
 Outdoor Air Temperature Senso	or:	Wired	Wireless				
EMS Signal Converter Kit (Converts Energy or Building Management System 0-10v signal to 4-20mA)							
 Motorized Isolation Valves							
Alarm Buzzer with Silencing Swi	itch						
PVC Starter Kit							
 Universal Communications Gateway (BACnet, Metasys, Modbus or Lonworks)							
 Conductor Sequencing Panel							
The Conductor manages multiple condensing & non-condensing, small & large heat output, new and/or existing boilers (full modulation or on-off), and steam or hot water applications. It helps improve system efficiency by selecting and modulating the right boiler to match operating conditions. The Conductor offers a single point boiler plant Energy Management System (EMS) interface including Modbus TCP/IP, Modbus RTU RS485, BACnet/IP and BACnet MSTP standard. If Lonworks needed, add for the separate Lonworks gateway.							
Extended Warranty							
3-Year Parts	5-Year Parts	10-Year Parts	5-Year Parts	s/Labor 10-Y	ear Parts/Labor		

### **BOILER EQUIPMENT**

Concert <sup>™</sup> Control (24 Vac) High Limit Temp Control, Manual Reset Low water cutoff, manual reset Water Flow Switch Supply & Return Water Temperature Sensors Flue Gas Temperature Sensor Condensate trap Blocked Condensate Switch Pressure & Temperature Gauge

ASME Relief Valve

(Available 30, 50, 60, 75, 100, 125 or 150 psig)

#### **ELECTRICAL DESIGN**

- Models 400-500:
- 120 VAC Only
- Amp Draw: 7.0 Amps

## Models 650-1000L:


- 120 VAC Only
- Amp Draw: 8.0 Amps
- PCB (Printed Circuit Board) Fused Connections

### 24VAC/5VDC - Low Voltage PCB

- EMS Communications
- (Dual RJ45 Jacks for Peer-To-Peer or ModBus)
- Boiler Options (Sensors)
- Pumps (Boiler, DHW, System) & Auxiliary Devices

# **BFIT CONDENSING BOILERS - SUBMITTAL DATA SHEET**

CONCERT CONTROL FEATURES



### Dashboard - Color Touchscreen Display, 4"

Intuitive Icon Navigation "Quick" Setup Menus \*Real Time BTU/H Display

#### Two (2) Temperature Demand Inputs

Outdoor Air Reset Curve for Each Input

Time of Day Setback Capability (Enviracom Thermastat must be installed)

#### m inermasiai musi be installed)

Three (3) Pump Control Boiler Pump With On/Off or Variable Speed Control

Domestic Hot Water (DHW) Pump

System Pump

Alternative Control to Combustion

Air Damper or Standby Loss Damper

Pump Overun for Heat Dissipation

Pump Exercise

Pump Rotor Seizing Protection

#### Peer-to-Peer Boiler Communications

Multiple Size Boiler Sequencing Up to 8 Units \*Two (2) Boiler Start/Stop Trigger

Lead Boiler Automatic Rotation

#### Energy Management System (EMS) Interface

 \*Firing Rate and Water Temperature Based Algorithms for Multiple Boilers; loss of EMS signal defaults to local boiler settings
420mAdc Input/Output (010Vdc Optional Converter)
ModBus Input/Output (BACnet or LonWorks Optional Gateway)
Simultaneous Interface with PeertoPeer

#### USB Data Port Transfer

Upload Settings Between Boilers Download Parameters for Troubleshooting Import Data into .CRV Formatted Files for Performance Analysis \* Unique to Concert



#### Energy Efficiency Enhancer AntiCycling Technology Multipler boiler base load common rate Outdoor Air Temperature Reset Curve Warm Weather Shutdown Boost Temperature & Time Ramp Delay OverTemperature Safeguarding Self-Guiding Diagnostics Identifies Fault Describes Possible Problems Provides Corrective Actions Time/Date Stamp on Alarms and Lockouts Unmatched Archives

Historical Trends Collects Up to 4 months Data Event History Up to 3000 Alarms, Lockouts and Cycle & Run Times Alarm Limit String Faults, Holds, Lockouts and Others Cycle & Run Time Boilers & Pumps Resettable (Lockouts/Alarms/Cycles & Run Time)

#### **Domestic Hot Water Priority**

DHW Tank Piped With Priority in the Boiler Loop DHW Tank Piped as a Zone in the System With the Pumps Controlled by the Concert Control DHW Modulation Limiting Status Screens Sensor Monitoring and Control Other Features Factory Default Settings

Three Level Password Security Frost Protection Contractor Contacts (Up to 3) Low Water Flow Safety Control & Indication Proportion Integral Derivative (PID) Parameters for

Central Heat, DWH, Sequencer and Fan